


E33434



Mounting adapter for process sensors

ADAPT IFM-TANK SPUD AV



- 1 Aseptoflex Vario
- 2 Leakage port
- 3 sealing area



EC 1935/2004 FCM FDA

Application		
Design	accessories for, PY200x, PM17xx, PI27xx, PG27xx, : Rosemount 1199 (SSW) Tank Spud Seal	
Pressure rating	34 bar	3.4 MPa
Tests / approvals		
Pressure equipment directive	A possible classification to PED depends on the application and has to be carried out by the user / operator.	
Safety instructions	The compatibility between medium and product material has to be checked in all applications.	

E33434



Mounting adapter for process sensors

ADAPT IFM-TANK SPUD AV

Mechanical data	
Weight	[g] 1602
Materials (wetted parts)	stainless steel (1.4435 / 316L) surface characteristics: Ra < 0,4 µm / Rz = 4 µm; O-rings: EPDM
Sensor connection	G 1 Aseptoflex Vario
Process connection	Tank Spud Rosemount 1199 (SSW) Tank Spud Seal
Sealing	Gasket
Hygienic equipment class to DIN 11866	H4
Accessories	
Items supplied	O-ring: 1 x (24 x 2 mm), EPDM, FDA compliant, E30054
Accessories (optional)	O-ring: 24 x 2, FKM, FDA compliant, E30123
	sealing ring:, PEEK, FDA compliant, E30124
Remarks	
Pack quantity	1 pcs.